

## BRUHAT BENGALURU MAHANAGARA PALIKE

Office of the Medical Officer OF Health Bommanahalli Zone, Bangalore- 560068

NO BBMP/MOH/MDP/PR/94/2023-24

DATE:20/11/2024

### PERFORMA REGARDING NOC & SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certfited that an inspection team headed by **Dr.Nagaraj SK Medical Officer of Health** and **Shruthi N., Sr.H.I.** (Name Of Officers with designation) from **BBMP Health Department** (Name of Department /Office) Inspected the **Bangalore International Kids High, 20/A, First Main, New Saptagiri Layout, Subramanyapura, Hindustan Granite Road, Uttarahalli, Bangalore-560061.** (Name & Address of the school) on **06-11-2024** and found that the **Bangalore International Kids High** (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the College building & the campus as per the norms prescribed by the central/state/U.T.Govt.

The Above NOC is Valid for the Period of up to 20.11.2025.

Signature with Seal:

Name

Designation

**Dr. Nagaraj SK**  
**Medical Officer of Health**  
**BBMP Bommanahalli Zone**  
**ಬೊಮ್ಮನಹಳ್ಳಿ ವಲಯ**


**ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ**


To,  
Bangalore International Kids High,  
20/A, First Main, New Saptagiri Layout,  
Subramanyapura, Hindustan Granite Road,  
Uttarahalli, Bangalore-560061.

## WATER TESTING REPORT FROM PHED LAB (GOVT DEPT)

RURAL DRINKING WATER & SANITATION DEPARTMENT, GOK  
Banashankari, Bangalore-560070.

Bengaluru Urban Divisional Laboratory-  
NABL Accredited Laboratory Bangalore urban

| TEST REPORT   |  |           |   |  |                           |
|---|--|-----------|---|--|---------------------------|
| Bangalore International Kids High<br><br>20/A, First Main, New Saptagiri Layout, Subramanyapura,<br><br>Hindustan Granite Road, Uttarahalli, Bengaluru,<br><br>Karnataka 560061 |  |           | Report date: 04/11/2024   |  |                           |
|   |  |           | Report Number: 5451   |  |                           |
|   |  |           | Reference: TRF  |  |                           |
|   |  |           | Sample code: 5451   |  |                           |
|   |  |           | Date of Sample collection: 04/11/2024   |  |                           |
|   |  |           | Analysis start date: 05/11/2024   |  |                           |
|   |  |           | Analysis completion date: 05/11/2024  |  |                           |
| DISE Number: 29200142024  |  |           |   |  |                           |
| Sample Particulars: R.O water   |  |           | Sample Quantity: 1 Litter   |  |                           |
| Sl No   | Test                                       | Results   | Acceptable Limit IS 10500: 2012 RA:2018   | Permissible Limit IS 10500: 2012 RA:2018 | Protocol                  |
| 1   | pH Value @25°C Temp                        | 8.1       | 6.5-8.5   | No relaxation                            | IS 3025 (Part-11):2022    |
| 2   | Specific Conductance, µS/cm @25°C Temp     | 100       |   |  | IS 3025 (Part-14):2013    |
| 3   | Odour                                      | Agreeable | Agreeable   | Agreeable                                | IS 3025 (Part-5 & 6):2018 |
| 4   | Colour, Hazen Units                        | < 1.0     | 5   | 15                                       | IS 3025 (Part-4):2021     |
| 5   | Turbidity, NTU                             | 0         | 1   | 5  | IS 3025 (Part-10):2023    |
| 6   | Total Dissolved Solids, mg/l @180°C        | 60        | 500   | 2000                                     | IS 3025 (Part-16):2023    |
| 7   | Alkalinity as CaCO <sub>3</sub> , mg/l     | 21.5      | 200   | 600                                      | IS 3025 (Part-23):2023    |
| 8   | Total Hardness as CaCO <sub>3</sub> , mg/l | 20        | 200   | 600                                      | IS 3025 (Part-21):2009    |
| 9   | Calcium as Ca, mg/l                        | 4.8       | 75  | 200                                      | IS 3025 (Part-40):1991    |
| 10  | Magnesium as Mg, mg/l                      | 1.9       | 30  | 100                                      | IS 3025 (Part-46):2023    |
| 11  | Chloride as Cl, mg/l                       | 15        | 250   | 1000                                     | IS 3025 (Part-32): 1988   |
| 12  | Sulphate as SO <sub>4</sub> , mg/l         | Nil       | 200   | 400                                      | IS 3025 (Part-24): 2022   |
| 13  | Fluoride as F, mg/l                        | 0.1       | 1   | 1.5                                      | APHA 24rd Edition         |
| 14  | Nitrate as NO <sub>3</sub> , mg/l          | 3         | 45  | No relaxation                            | APHA 24rd Edition         |
| 15  | Iron as Fe, mg/l                           | Nil       | 1   | No relaxation                            | IS 3025 (Part-53) : 2023  |
| Remark: The above given sample conforms to the acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.                    |  |           |   |  |                           |
| Analysed by: Poornima.GS<br>Analyst/Junior Analyst  |  |           | Authorized Signatory:  Senior<br>Technical Manager: Vinutha MK |  |                           |



RDWSD/WQMSP/TeR/01

## Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01